

TEST CERTIFICATE

ST-17-03-16-01

Product: WPC Terrace floor
Profile "PREMIUM"

Client: WPC - Woodplastic a.s.
Bukovany 181
25741 Týnec nad Sázavou
Tschechische Republik

Order: Determination of the anti-slip properties according to DIN 51130:2014

Test report: 2717098

Test result:


Property	Result	Anti-slip class according to DIN 51130:2014
Anti-slip resistance according to DIN 51130:2014	$\alpha_{ges} = 15.6^\circ$	R10

α_{ges} ... Total acceptance angle

Dresden, 16 March 2017



Head of laboratory

Engineer in charge